



KEY

	TRAMMEL DRAIN
	S.W. SEWERS
	RISING MAIN (surface water)
	FOUL SEWERS
	RISING MAIN (Leachate/foul)
	LEACHATE DRAIN
	WATER MAIN
	ELEC CABLES AND DUCTS
	LIGHTING CABLES AND DUCTS
	LIGHTING COLUMN
	OVERHEAD ELECTRIC LINE
	TELECOM CABLES AND DUCTS
	CCTV CAMERA COLUMNS
	CCTV CABLES AND DUCTS
	FENCELINES
	Gate
	Hedge
	GAS EXTRACTION INFRASTRUCTURE
	LEACHATE MONITORING POINT
	GAS MONITORING BOREHOLE
	OFF SITE GROUND WATER SAMPLING POINT
	ACCESS CHAMBER/MANHOLE

DSEAR CLASSIFICATION


	Zone marking for Zone 0
	Zone marking for Zone 1
	Zone marking for Zone 2
	Borehole internal Zone 1
	Within 1/2 m radius of all the Boreholes are in Zone 2
	Manholes Zone 1
	Within 1m radius of the Manholes is in Zone 2
	LMC is in Zone 1
	Within 1m radius of all the LMC's are in Zone 2

Please refer MWDA.530-500-001-0 for Pumping Chamber number 1 [MHA1] details

Rev.	Amendment	Date
------	-----------	------

Site
FOUL LANE FORMER LANDFILL SITE

Title
**SITE INFRASTRUCTURE
DSEAR Regulations and Zoning**



A1	Dwg. No. MWDA.530-500-001	Rev. .
Drawn	Binu	Scale N.T.S
Date	DEC 11	