Meghull Brook

Adjacent FARM

Adjacent FARM

Adjacent FARM

Adjacent FARM

BRITISH GAS 400mm Dia HIGH PRESSURE GAS MAIN

REMNANTS OF CONCRETE POST AND PANEL FENCE

HEADWALL

BH25 BH24 BH23 BH22 BH21 BH20 BH19 BH18 BH17 BH16 BH15 BH14 BH13 BH12 BH11 BH10 BH9 BH8 BH7 BH6 BH5

Track

O/head elec

O/HEAD 33kV ELEC CABLE

Nom 1.0m HIGH POST AND WIRE FENCE

Drain

Dismantled Railway

600mm Dia

1050mm Dia

HILL HOUSE SEWER

ETL

HILLHOUSE

SW-MH03

Pump Chamber PC2
(Refer MWDA520.3-100-001)

TOWER

BH26 BH27 BH29 BH31 BH32 BH33 BH34 BH35 BH36 BH37 BH38 BH3 BH2 BH1 BH43 BH42

MH03 MH02 MH01

SW-MH02 SW-MH01

Sefton Meadows Extension 2

Household Waste Reception Centre

ACCESS TO FORMER LANDFILL SITE

RIVER ALT

Water Course

Dover's Brook

Ditch

VEHICULAR ACCESS FROM HWRC

Storm Water Lagoon

Bldg

EM

Access to Lagoon & Power Compound

LEVEE

Outfall

River Alt

SLOAD BRIDGE (A565)

Sload Brook

Glaisdale

VC1

Pipe Bridge
(Refer HD 6917)

Sefton Meadows EAST

Sefton Meadows WEST

Sefton Meadows Extension 3

Field

Ditch

LEGEND

- S.W. SEWERS
- FOUL SEWERS
- RISING MAIN (Leachate/foul)
- BH‡ BOREHOLES
- MH 17◎ MANHOLES/CHAMBERS
- STEEL TOWERS FOR ETL
- POLE MOUNTED TRANSFORMER
- FENCELINE

DSEAR

- Zone0 Zone marking for Zone 0
- Zone1 Zone marking for Zone 1
- Zone2 Zone marking for Zone 2
- Borehole Internal Zone 1
- Within 1/2 m radius of Boreholes - Zone 2
- Within 1 m radius of Boreholes 29, 36, 43, 44, 46, 71, 73, 74 & 75 - Zone 2
- Manholes Internal - Zone 1
- Within 1m radius of Manholes - Zone 2

Rev.	Amendment	Date

Site: SEFTON MEADOWS 2

Title: SITE INFRASTRUCTURE
DSEAR Regulations and Zoning

MWDA
Merseyside Waste Disposal Authority
6th Floor
North House
North John Street
Liverpool
L2 6QY

AO	Drg. No. MWDA.520.2-500-001	Rev. 0

Drawn	BINU	Scale	1:1000	Date	OCT 12